

ADDENDUM NO. 2

HARRIS COUNTY W.C. & I.D. NO. 110

ADDITIONAL CHLORINE CONTACT CHAMBER AT WASTEWATER TREATMENT PLANT

JOB NO. 078-278, CONTRACT NO. 1

Plans:

1. Drawing S4 (Sheet 13 of 14):

Detail 1/S4 – handrail should be on both sides of stair, detail shows one side only.

2. Drawing S4 (Sheet 13 of 14):

Detail 6/S4 – detail shows a stainless steel base plate and a galvanized column, both should be galvanized.

